

Department of Regulatory and Economic Resources

Environmental Resources Management Code Coordination & Environmental Initiatives 701 NW 1st Court 4th Floor Miami, Florida 33136-3912 T 305-372-6764 F 305-372-6759

miamidade.gov

January 23, 2025

Stephanie Puglia 8401 NW 53 Terrace, 2nd Floor Doral, FL 33166

Re: Municipal Site Plan Review #MZ2024000064- 1st Review

Eurocon LLC

3265 NW 107 Ave, Doral, Florida 33172

Zoning classification change from Office 3 to MF-4 with Special Development Requirements

City of Doral process number LAND-2405-0016

Folio no: 35-3029-100-0010

Dear Ms. Puglia:

The Department of Regulatory and Economic Resources – Division of Environmental Resources Management (DERM) has reviewed the above referenced Municipal Site Plan Review for compliance with the requirements of Chapter 24 of the Miami-Dade County Code (the Code) for potable water service, wastewater disposal and wellfield protection. Based on the information provided, this site plan review is approved pursuant to Sections 24-43.1 of the Code.

Potable Water Supply and Wastewater Disposal

According to DERM records the property is connected to public water and sanitary sewers. Pursuant to the Code and based on the proposed site plan, the proposed redevelopment shall connect to public water and sanitary sewers in accordance with Code requirements. To the extent that connection to the public sanitary sewer system is not approved due to a sanitary sewer moratorium, this memorandum shall not be interpreted as written approval from DERM to allow an alternative means of domestic wastewater disposal.

Please note that some of the collection/transmission facilities, which includes sanitary sewer gravity sewer mains, sanitary sewer force mains and sanitary sewer pump stations, throughout the County do not have adequate capacity, as defined in the Consent Decree between Miami-Dade County, Florida Department of Environmental Protection, and the U.S. Environmental Protection Agency case 1:12-cv-24400-FAM. Under the terms of this Consent Decree, this approval does not constitute an allocation or certification of adequate treatment and transmission system capacity. At the time of building permits DERM will evaluate and may reserve sanitary sewer capacity, through the DERM sanitary sewer certification process, if the proposed development complies with the provisions of the Consent Decree. Building permits for development in sanitary sewer basins which have been determined not to have adequate capacity cannot be approved, until adequate capacity becomes available.

Please be advised, DERM review and approval is required for any proposed public or private sanitary sewer system. Each parcel within the proposed development that is required to be served by public



sanitary sewers shall connect directly to the public sanitary sewer system, without traversing other parcels. Private sanitary sewer collection and transmission systems are limited to one building per parcel connecting directly to a public sanitary sewer system and cannot traverse other parcels to connect to the public sanitary sewer system. If multiple buildings are within a parcel, each building shall connect individually to a public sanitary sewer system without traversing other parcels.

Stormwater Management

DERM had previously approved a Surface Water Management General Permit for this site via Permit 13-05330-P. The site plan provided with this application proposes changes to the site plan approved under Permit 13-05330-P. Therefore, a DERM Surface Water Management General Permit modification shall be required for any development. This permit shall be obtained prior to any future development order approval. The applicant is advised to contact the DERM Water Control Section at (305)372-6681 or dermwatercontrol@miamidade.gov for further information regarding permitting procedures and requirements.

The review of the above noted plans shall not constitute DERM approval of the paving and drainage plans included in this application. Paving and drainage plans shall be reviewed and approved by the RER Environmental Plan Review office.

Tree Preservation

An aerial review of the subject property indicates the presence of tree resources. A tree disposition plan entitled "Ritz Sky Mansions at Doral" prepared by Scott F. Neitszel, R.L.A., was submitted in support of the subject application and indicates the removal/relocation of non-specimen tree resources. Section 24-49 of the Code provides for the preservation and protection of tree resources. DERM has no objection to this application provided that the applicant obtains a Miami-Dade County Tree Removal Permit prior to the removal or relocation of the non-specimen trees on site.

A Miami-Dade County Tree Permit is required prior to the removal and/or relocation of any tree that is subject to the tree preservation and protection provisions of the Code. The applicant is advised that a tree survey that includes a tree disposition table will be required during the tree removal permit application process. Projects and permits shall comply with the requirements of sections 24-49.2 and 24-49.4 of the Code, including the specimen tree standards.

In accordance with section 24-49.9 of the Code, all plants prohibited by Miami-Dade County shall be removed from all portions of the property prior to development, or redevelopment and developed parcels shall be maintained to prevent the growth or accumulation of prohibited species. Please contact Jackelyn Alberdi at Jackelyn.Alberdi@miamidade.gov for additional information or concerns regarding this review.

Enforcement History

There are no open or closed enforcement records for violations of Chapter 24 of the Code for the subject property. There are no outstanding DERM liens or fines for the subject property.



If you have any questions concerning the comments or wish to discuss this matter further, please contact Ninfa Rincon at (305) 372-6764.

Sincerely,

Lisa M. Spadafina, Director

Lise Sparagina

Division of Environmental Resources Management