



Department of Regulatory and Economic Resources

Environmental Resources Management
Code Coordination & Environmental Initiatives
701 NW 1st Court 4th Floor
Miami, Florida 33136-3912
T 305-372-6764 F 305-372-6759

miamidade.gov

June 23, 2025

Stephanie Puglia
8401 NW 53 Terrace, 2nd Floor
Doral, FL 33166

Re: Municipal Site Plan Review #MZ2025000025-1st Review
Publix Super Markets, Inc.
9705 NW 41st Street
City of Doral Application PLAN 2410-0092
Proposing re-development of existing Publix

Folio no. 35-3020-012-0020

Dear Ms. Puglia:

The Department of Regulatory and Economic Resources – Division of Environmental Resources Management (DERM) has reviewed the above referenced Municipal Site Plan Review for compliance with the requirements of Chapter 24 of the Miami-Dade County Code (the Code) for potable water service and wastewater disposal. Based on the information provided, this site plan review is approved pursuant to section 24-43.1 the Code. With respect to other issues discussed herein DERM does not object to this application provided that all the conditions contained herein are complied with.

Potable Water Supply and Wastewater Disposal

According to DERM records the existing building is connected to public water and sanitary sewers. Pursuant to the Code and based on the proposed site plan, the proposed development shall connect to public water and sanitary sewers in accordance with Code requirements. To the extent that connection to the public sanitary sewer system is not approved due to a sanitary sewer moratorium, this memorandum shall not be interpreted as written approval from DERM to allow an alternative means of domestic wastewater disposal.

Please note that some of the collection/transmission facilities, which includes sanitary sewer gravity sewer mains, sanitary sewer force mains and sanitary sewer pump stations, throughout the County do not have adequate capacity, as defined in the Consent Decree between Miami-Dade County, Florida Department of Environmental Protection, and the U.S. Environmental Protection Agency case 1:12-cv-24400-FAM. Under the terms of this Consent Decree, this approval does not constitute an allocation or certification of adequate treatment and transmission system capacity. At the time of building permits DERM will evaluate and may reserve sanitary sewer capacity, through the DERM sanitary sewer certification process, if the proposed development complies with the provisions of the Consent Decree. Building permits for development in sanitary sewer basins which have been determined not to have adequate capacity cannot be approved, until adequate capacity becomes available.

Stormwater Management

Any development/ redevelopment involving 2 acres or more of impervious area shall require a DERM Surface Water Management General Permit for the construction and operation of the required surface water management system. This permit shall be obtained prior to any future development order approval.

Stormwater shall be retained on site utilizing designed seepage or infiltration drainage system. Drainage plans shall provide for full on-site retention of the stormwater runoff generated by a 25-year, 3-day storm event. Any proposed development shall comply with county and federal flood criteria requirements.

The applicant is advised to contact the DERM Water Control Section (305)372-6681 for further information regarding permitting procedures and requirements.

The review of the above noted plans shall not constitute DERM approval of the paving and drainage plans included in this application. Paving and drainage plans shall be reviewed and approved by the RER Environmental Plan Review office.

Tree Preservation

An aerial review of the subject property indicates the presence of tree resources. A site plan entitled "Publix at Doral Plaza Store No. 0031" prepared by Nelson H. Ortiz, P.E., was submitted in support of the subject application and indicates the removal/relocation of non-specimen (a tree with a trunk diameter at breast height less than 18 inches) tree resources. Section 24-49 of the Code provides for the preservation and protection of tree resources. DERM has no objection to this application provided that the applicant obtains a Miami-Dade County Tree Removal Permit prior to the removal or relocation of the non-specimen trees on site.

A Miami-Dade County Tree Permit is required prior to the removal and/or relocation of any tree that is subject to the tree preservation and protection provisions of the Code. The applicant is advised that a tree survey that includes a tree disposition table will be required during the tree removal permit application process. Projects and permits shall comply with the requirements of sections 24-49.2 and 24-49.4 of the Code, including the specimen tree standards.

In accordance with section 24-49.9 of the Code, all plants prohibited by Miami-Dade County shall be removed from all portions of the property prior to development, or redevelopment and developed parcels shall be maintained to prevent the growth or accumulation of prohibited species. Please contact Jackelyn Alberdi at Jackelyn.Alberdi@miamidade.gov for additional information or concerns regarding this review.

Air Quality Management

The proposed development would require the demolition of existing structures. 40 CFR Part 61 Subpart M - National Emission Standards for Hazardous Air Pollutants (NESHAP) for Asbestos provides that an asbestos survey from a Florida-licensed asbestos consultant is required for renovation activities surpassing the NESHAP threshold of suspect regulated asbestos containing materials (RACM), and for all demolition activities.



“Demolition” is defined as the wrecking or taking out of any load-supporting structural member of a facility together with any related handling operations, or the intentional burning of any facility.

The NESHAP thresholds for RACM are 260 linear feet of RACM on pipes, or 160 square feet of RACM on other facility components.

If the Asbestos Survey identifies materials (friable or to be made friable during the proposed renovation/demolition activities) containing more than 1 percent asbestos and the amount is over the regulated thresholds, then those materials must be removed/abated prior to renovation/demolition activities by a Florida-licensed asbestos abatement contractor. An Asbestos Renovation Notification must be filed, and obtain approval, with the Miami Dade County - Department of Regulatory and Economic Resources, Division of Environmental Resources Management - Air Quality Management (AQM), at least 10 working days (14 calendar days) prior to starting the abatement work. Regardless of asbestos content, prior to any demolition work, an Asbestos Demolition Notification must be submitted and approved, within the same timeframes.

For question regarding asbestos surveys and notifications, please contact the AQMD via email at asbestos@miamidade.gov.

Enforcement History

The subject property has no open and two (2) closed formal enforcement records for violations of Chapter 24 of the Code. Please contact the Enforcement Section if you require additional information. There are no outstanding DERM liens or fines for the subject property.

LLS Enterprises, INC. DBA Subway @ Doral Plaza (DERM closed case no. GDO-4791, UCVN no. B207612)

Unpaid penalties: \$0.00

Paid penalties & surcharge: \$410.00 (civil penalty and surcharge for UCVN No. B207612)

The Moose Man, INC. (DERM closed case no. GDO-5074, UCVN no. B237579)

Unpaid penalties: \$0.00

Paid penalties & surcharge: \$110.00 (civil penalty and surcharge for UCVN No. B237579)

If you have any questions concerning the comments or wish to discuss this matter further, please contact Ninfa Rincon at (305) 372-6764.

Sincerely,

A handwritten signature in blue ink that reads "Lisa M. Spadafina".

Lisa M. Spadafina, Director
Division of Environmental Resources Management